B-U-C-K-S-L-I-P

To: File
From: Kelly Avenoso
Date: March 10, 1992
Subject: 1WTC Elevators # 12, 14, 21

CC: P. Leahy, R. Peduto

Consistent with WT Department's development of an air sampling and inspection of the elevator cars and shafts, air sampling pumps will be running on top of 5 shuttle elevators from 1-78th floor. The elevators will be operating during the sampling period.

The air samples were analyzed and the results were as follows:

12 ; <.006
14 ; <.006

Material was found on the top of elevator shuttle cars 12, 14, and 21. These elevators share a shaft with 13, 15, and 20, respectively.

The material was analyzed and the results were as follows:

12 : Two + 21 : Two +
14 : One - One -

An air monitoring and cleanup program is being developed by WT Department. To date, air monitoring has been performed in all of the 1WTC shuttle elevator cars from 1-44th floor except passenger elevator shaft # 10/11, and freight elevator shaft #5.

PLAINTIFF'S EXHIBIT
PX-730